

November 24, 2021

Re: ADDENDUM NO. 1

Roxbury Improvements District  
Sewer Lift Station Improvements  
WCI File: 21-600-157-00/01/8640/8600

To All Prospective Bidders:

The Contract Documents for the referenced project are hereby amended in the following particulars only, with all other conditions remaining unchanged.

A. DRAWINGS

1. Sheet No. E-101, Electrical Plan and Section  
**REMOVE** all references to the gas detection system with strobe and horn. The gas detector will not be installed as part of this project.
2. Sheet No. E-501, Electrical Details  
**REMOVE** all references to the gas detection system with strobe and horn on Detail E5. The gas detector will not be installed as part of this project.
3. Sheet No. E-501, Electrical Details  
**REMOVE** Detail D5. The gas detector will not be installed as part of this project.
4. Sheet No. E-601, One Line Diagram  
**REMOVE** the combustible gas detector from the Panelboard LA Schedule and replace with Space. The gas detector will not be installed as part of this project.
5. Sheet No. E-601, One Line Diagram  
**CHANGE** General Electrical Note 10 to read “ALL CHARGES FROM THE UTILITY TO INSTALL AND/OR MODIFY THE ELECTRICAL SERVICE TO THESE FACILITIES SHALL BE PAID BY THE CONTRACTOR.”

This ADDENDUM is hereby made a part of the Bidding Documents to the same extent as though contained in the original documents. Work to be included shall not be limited to narrative description contained herein but shall also include adjustments or revisions to other work not mentioned, in order to accomplish the Work described.

Each Bidder shall acknowledge receipt of this ADDENDUM in the space provided on the Bid Form.

WILSON & COMPANY

A handwritten signature in blue ink, appearing to read 'Travis Hamel', is positioned below the company name.

Travis Hamel  
Project Manager  
785-820-2656  
Travis.hamel@wilsonco.com